

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)  
Notified Body Nr. 0370

No. **0370-CPR-7391**

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

## FIRE DETECTION AND FIRE ALARM SYSTEMS:

- MANUAL CALL POINTS

REFERENCE: **JBE-2401, JB-2402**

Placed on the market under the name of:

## JADE BIRD FIRE ALARM INTERNATIONAL (EUROPE), S.L.

C/ DE TARRAGONA, 157 7º  
08014 BARCELONA (SPAIN)

And produced in the manufacturing plant:

**24/32307237**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 54-11:2001, EN 54-11:2001/A1:2005**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 10<sup>th</sup> January 2025 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**The monitoring assessment will be done before 30<sup>th</sup> September 2025**

Bellaterra, 10<sup>th</sup> January 2025



**Applus<sup>+</sup>**  
LGAI Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*This document is not valid without its technical annex; whose number coincides with that of the certificate.*

*You can check the validity of this certificate on our website: [www.appluslaboratories.com/certified\\_products](http://www.appluslaboratories.com/certified_products)*

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

## 0370-CPR-7391

Annex according to **EN 54-11:2001, EN 54-11:2001/A1:2005**

### FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 11: MANUAL CALL POINTS

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Marking and data	4.2	PASS
Normal condition	4.3.1	PASS
Alarm condition	4.3.2	PASS
Indicators for alarm condition	4.4	PASS
Reset facility	4.5	PASS
Test facility	4.6	PASS
Safety aspects	4.7.1	PASS
Shape, dimensions and colours	4.7.2	PASS
Symbols and lettering	4.7.3	PASS
Protection against accidental operation	4.7.4	PASS
Environment category	4.7.5	PASS
Additional requirements for software controlled manual call points	4.8	NA
Operational performance test	5.2	PASS
Function test	5.3	PASS
Test facility test (operational)	5.4	PASS
Reliability test (endurance)	5.5	PASS
Variation of supply parameters	5.6	PASS
Dry heat (operational)	5.7	PASS
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	PASS
Damp heat, cyclic (operational)	5.10	PASS
Damp heat, cyclic (endurance)	5.11	NA
Damp heat, steady state (endurance)	5.12	PASS
SO2 corrosion (endurance)	5.13	PASS
Shock (operational)	5.14	PASS
Impact (operational)	5.15	PASS
Vibration, sinusoidal (operational)	5.16	PASS
Vibration, sinusoidal (endurance)	5.17	PASS
Electromagnetic compatibility (EMC) (operational)	5.18	NA
Enclosure protection	5.19	NA

PASS; NPD = No Performance Determined; NA = Not Applicable

ACCESORIOS	
TBD-200	Protective plastic cover for indoor manual call points
SMP-200	Manual call point base